



## GVEV.R26997 Swinging Fire Door Closers

[Page Bottom](#)

---

### Swinging Fire Door Closers

[See General Information for Swinging Fire Door Closers](#)

#### **WATERSON CORP**

R26997

8TH FL, 428 WUQUAN S RD  
SOUTH DISTRICT  
TAICHUNG, 402 TAIWAN

For self-closing doors, without hold-open feature, single acting spring hinge type, K51M Series with 3.5 in., 4.0 in., 4.5 in. and 5.0 in. leaf height.

For self-closing doors, without hold-open feature, single acting swing clear spring hinge type, K51L Series with 4.0 in., 4.5 in. and 5.0 in. leaf height.

#### Note:

Door closers of the spring-hinge type are investigated using the cycle endurance test in ANSI/BHMA A156.17, Grade 1, "Self Closing Hinges and Pivots".

[Last Updated](#) on 2015-10-21

---

[Questions?](#)

[Print this page](#)

[Terms of Use](#)

[Page Top](#)

◆ 2015 UL LLC

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2015 UL LLC".